

SHANGHAI COLORBO INDUSTRIAL CO.,LTD

TEST REPORT

SCOPE OF WORK

PET Acoustic Panel

REPORT NUMBER

210623014SHF-001

TEST DATE(S)

2021-06-23 - 2021-07-01

ISSUE DATE

2021-07-01

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2021)

© 2021 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.
- 7.The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.

Test Report

Issue Date: 2021-07-01 Intertek Report No. 210623014SHF-001
Applicant: SHANGHAI COLORBO INDUSTRIAL CO.,LTD
Address: Rm 101-202, No.1 Block, Changzheng Design Center
1412 Tongpu Road, Putuo District, Shanghai, 200333
Attn: Dongying Zhang
Manufacturer: SHANGHAI COLORBO INDUSTRIAL CO.,LTD
Address: Rm 101-202, No.1 Block, Changzheng Design Center
1412 Tongpu Road, Putuo District, Shanghai, 200333
Test Type: Performance test, samples provided by the applicant.

Product Information

Product Name	PET Acoustic Panel	Brand	COLORBO
Sample Description	Good Condition	Sample Amount	1 package
		Received Date	2021-06-23
Sample ID	Model	Specification	
S210623014SHF.001	PFOA-12	12mm	

Test Methods And Standards

Test Standard	With reference to EPA 3052
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1. This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized



 Name: Flora Fan Name: Vincent Ding
 Title: Reviewer Title: Project Engineer

Test Report

Issue Date: 2021-07-01

Intertek Report No. 210623014SHF-001

Test Items, Method and Results:

Test Item: Total Elements Content

Test Method: With reference to EPA 3052, acid digestion method was used and total Elements content was determined by Inductively Coupled Argon Plasma Spectrometry.

Test Item	Test Result (ppm)
Antimony (Sb) Content	261
Arsenic (As) Content	ND
Chromium (Cr) Content	ND
Copper (Cu) Content	ND
Selenium (Se) Content	ND
Tin (Sn) Content	ND

Note:

1. ppm = parts per million = mg/kg
2. Detection Limit = 10 mg/kg
3. Test location: Central Chemical Lab of Intertek Testing Services Ltd., Shanghai
Address: Block B, Jinling Business Square, No.801, Yi Shan Road, Shanghai, China

Test Report

Issue Date: 2021-07-01

Intertek Report No. 210623014SHF-001

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes
210623014SHF-001	2021-07-01	First issue